



NOTES:

1. FULLY ENCOMPASS CORPORATION STOP WITH STONE.
2. METER BOX TO BE LOCATED ON THE RIGHT-OF-WAY SIDE OF PROPERTY LINE.
3. WHEN METER BOX IS SET IN SIDEWALK, PIGTAIL TO EXTEND 2 FEET BEYOND EDGE OF SIDEWALK.
4. FITTING TO BE USED WHEN CONNECTING TO EXISTING SERVICE, OTHERWISE CRIMP END OF SERVICE LINE.
5. METER & EXPANSION WHEEL TO BE FURNISHED & INSTALLED BY CITY.
6. FITTINGS CAN BE EITHER FLARED OR COMPRESSION.
7. THERMAL EXPANSION MUST BE ADDRESSED.
8. THIS DETAIL IS FOR NEW CONSTRUCTION ONLY. SEE SPECIFICATIONS FOR SERVICE REPLACEMENT PROJECTS.



THE CITY OF LYNCHBURG

3/4 INCH WATER SERVICE
(1 INCH WATER SERVICE SIMILAR)
(NEW CONSTRUCTION ONLY)

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:
NOT TO SCALE

REVISION DATE:
11-06-2006

DETAIL #
26.12B

SHEET #:
1 OF 1